

POWER WIRING

DDC 110 CONDENSER ELECTRICAL CONTROL PANEL WIRING

LEGEND

C — COMPRESSOR CONTACTOR
CF — CONDENSER FAN CONTACTOR
O/L — OVERLOAD
BP — BRINE PUMP CONTACTOR
TD — TIME DELAY RELAY
R — RELAY
□ — TERMINAL BLOCK

LP - LOW PRESSURE SWITCH
HP - HIGH PRESSURE SWITCH
HOT - HIGH DISCHARGE THERMOSTAT
OFS - OIL FAILURE SWITCH
RAHP - REVERSE ACTING HIGH PRESS. SW.
HM - ELAPSED TIME METER
CR - CONDENSER RELAY

Please note
oil failure later when next time delay's
3 1/4 through pump down switches

CONTROL WIRING

2	AS-BUILT DRAWING ALTERED	DEC 11,89	G.L.
1	AS-BUILT DRAWING	NOV 28,89	
REV. #	REVISION	DATE	BY

Fleming Pedlar LTD.

HEAD OFFICE: 565 MUNROE AVE, WINNIPEG, MB, R2K 1H7
1-204-667-7863

AIR CONDITIONING
STORE FIXTURES
REFRIGERATION
HEATING

DRWN: G.L.

CHKD;

AS-BUILT ELECTRICAL
FOR
DON BOSS ARENA

SCALE:
N/A